

2024 Cuba Water System Consumer Confidence Report

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies. Last year, we conducted tests for over 80 contaminants. We only detected 12 of those contaminants, and found only 2 at a level higher than the EPA allows. As we informed you at the time, our water temporarily exceeded drinking water standards. (For more information see the section labeled Violations at the end of the report.)

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Cuba Water System gets its water from three wells that is then disinfected before entering distribution.

Source water assessment and its availability

The NM Environment Department completed a source water assessment. If you would like more information regarding the source water assessment, please contact the NMED-Drinking Water Bureau at 1-505-476-8620 or toll free 1-877-654-8720.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Please attend monthly commission meetings.

Monitoring and reporting of compliance data violations

Cuba Water System received a violation on August 15, 2013th that lasted until 2024 for not providing the required public notices for violations. Public water systems must notify customers of the violation by mail or other direct delivery to each customer and any other methods as necessary to inform the public, within one (1) year from the date of the original NOV and certify that the notice was published and the method of publication by submitting a completed Public Notification Certification Form to NMED within ten (10) days of completing the public notification requirements

Cuba received a violation on October 6, 2024, for failing to submit the required 2023 Consumer Confidence Report by July 1, 2024 to its members. Cuba will return to compliance upon submittal of the Consumer Confidence Report to its members. Cuba received a violation on November 5, 2024, for failing to certify to the NM Environment Department that the 2023 CCR was provided to its members. Cuba will return to compliance once we certify to the NMED that the CCR was provided to its members.

Cuba received a violation on September 5, 2024, for failing to sample for lead and copper within the required sample schedule frequency for the sampling cycle. Cuba returned to compliance at the next sampling event.

Coliform Bacteria

Cuba samples for total coliform bacteria on a monthly basis. In 2024, Cuba had 2 positive samples for total coliform. Cuba was required to do additional sampling that resulted in no further action. Follow up E.Coli testing was negative and there was no violation from the sampling.

Significant Deficiencies

Cuba Water System received violations related to Sanitary Survey Deficiencies on December 20, 2018 and on December 3, 2021. Those violations ended in April 2024.

Administrative Order

NMED –Compliance and Enforcement Bureau filed an Administrative Order against the Village of Cuba Community Water System (Docket#2022-ACO-03) on January 24, 2022, for three (3) violations: 1. Failure to submit a Corrective Action Plan (CAP) for the 2021 Sanitary Survey. 2. Failure to correct significant deficiencies from the 2018 and 2021 Sanitary Surveys. 3. Failure to deliver the 2019 and 2020 calendar year Consumer Confidence Reports (CCR).

Additional Information for Lead

Our system inventory includes unknown service lines. Members can request a copy of the lead service line inventory by contacting 505-290-9248 or emailing Mayorherrera63@gmail.com.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. CUBA WATER SYSTEM is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and

removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact CUBA WATER SYSTEM (Public Water System Id: NM3509023) by calling 505-290-9248 or emailing Mayorherrera63@gmail.com. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl2) (ppm)	4	4	1.0	0.6	1	2024	No	Water additive used to control microbes

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source	
				Low	High				
Haloacetic Acids (HAA5) (ppb)	NA	60	1	0.64	1.1	2023	No	By-product of drinking water chlorination	
TTHMs [Total Trihalomethanes] (ppb)	NA	80	7.4	6.4	7.4	2023	No	By-product of drinking water disinfection	
Inorganic Contaminants									
Barium (ppm)	2	2	0.028	0.025	0.028	2024	No	Discharge of drilling wastes and metal refineries;Erosion of natural deposits	
Fluoride (ppm)	4	4	0.23	0.16	0.23	2024	No	Erosion of natural deposits; Additive to promote strong teeth; Discharge from fertilizer and aluminum factories	
Nitrate (measured as Nitrogen) (ppm)	10	10	0.16	0	0.16	2024	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	
Radioactive Contaminants									
Beta/photon emitters (pCi/L)	00	50	4.2	NA	NA	2022	No	Decay of natural and man-made deposits.	
Radium (combined 226/228) (pCi/L)	00	5	0.44	NA	NA	2023	No	Erosion of natural deposits	
Contaminants	MCLG	AL	Your Water	Range		# Samples Exceeding AL	Sample Date	Exceeds AL	Typical Source
				Low	High				
Inorganic Contaminants									
Copper - action level at consumer taps (ppm)	1.3	1.3	0.12	0.011	0.15	0	9/29/2021	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	00	15	5.8	0	11	0	9/29/2021	Yes	Corrosion of household plumbing systems; Erosion of natural deposits

Violations	
None	

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
mrem/yr	mrem/yr: millirems per year (a measure of radiation absorbed by the body)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Important Drinking Water Definitions	
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level
90th Percentile	Compliance with the lead and copper action levels is based on the 90th percentile lead and copper levels. This means that the concentration of lead and copper must be less than or equal to the action level in at least 90% of the samples collected.

For more information please contact:

Contact Name: HERRERA, DENNY
Address: PO Box 426
CUBA, NM 87013
Phone: 505-290-9248